

ORC Water Professionals

Operations Report

August 2015

Prepared by: Ernest Espinosa, Facilities Operator

Hi-Land Acres Water and Sanitation District

North Well

The following events occurred at the North well over the course of the previous month.

- The vegetation surrounding the water treatment plant is in need of mowing, weed trimming.
- The North Well is functioning very well.

- Still will need to review:
 - ORC was informed that the south fencing surrounding the North Well will need to be moved back 4 feet for Electrical Safety Requirements (ESR).
 - This will safely allow certified persons to access the North Wells Meter Box and Fuse Disconnect Box.
 - Minimum safe distance is 4 feet from panel door opening.

WTP & Distribution System .

- The meter readings were sent to AMCOBI on July 31, 2015.
- ORC has received two new meters from National Meter.

South Well .

- ORC is still currently looking into long term solution for plants water hammer issues.
- The vegetation surrounding the water treatment plant and access paths are in need of mowing, weed trimming and debris removal.

WWTP

Collection System

- ORC is proceeding with Dana Kepner for ordering:
 - Three manholes are in need of rising on the North side of Hi Land Acres due to depth and location near resident's property.
 - Two additional Water Valves located on easement road will need to be elevated.