

ORC Water Professionals

Operations Report

March 2016

Prepared by:

Gabrielle Begeman, Operations and Compliance Manager

Hi-Land Acres Water and Sanitation District

North Well

- The depth of water over the well pump was measured at 180 feet above the pump.
- The production coming out of the well is still decreased from what it used to be. It maybe beneficial to have the pump pulled to determine the cause of the problem.

South Well

- The depth of the water over the well pump was measured to be 210 feet of water.
- The south well system has been working well with no issues.

WTP & Distribution System

- The meter readings were sent to AMCOBI on 3-30- 2016.
- Please see the attached exceptions report for March.
- A leak was found on the hydrant at the end of 159th Ave. The hydrant valve was shut which stopped the leak. The hydrant was exercised in an attempt to seat the valve and stop the leak. The effort failed and the leak reappeared. The hydrant has been turned off at the hydrant valve.
- Please see the attached quote for installing a sodium hypochlorite system on both of the wells for disinfection.

WWTP & Collection System

- The plans and specs were sent to Barnard Construction for review and potential bid on the project.



ORC Water Professionals
 11919 W. I - 70 Frontage Road #116A
 Wheat Ridge, CO 80033

Work Order

Approval Form

Date: 03/17/16
 W.O. #: 104
 Customer ID: Hi-Land Acres W

Bill to: Hi-Land Acres Water and Sanitation District
 PO Box 218
 Brighton, CO 80601

Job: WTP Chlorine Conversion

Qty	Description	Unit Price	Line Total
3.00	Chemical Pumps	\$ 650.00	\$ 1,950.00
3.00	Chemical Day tank	150.00	450.00
3.00	Secondary Containment	130.00	390.00
1.00	Misc Piping	200.00	200.00
10.00	Hourly labor to install	75.00	750.00
Subtotal			\$ 3,740.00
Sales Tax			
Total			\$ 3,740.00

Preapproval for work must received by ORC by email or fax before any work will proceed.

Print Name of Representative

Phone

Signature of Representative

Date

Thank you for your business!

ORC Water Professionals

11919 W. I - 70 Frontage Rd. #116A, Wheat Ridge, CO. 80033

Office: 720 287-0605 Fax: 720 287-0874

Hi-Land Acres - Exceptions Report - 03/30/2016

Account ID	Last Name	Read Type	Reader Initials	Read Code 1	High Limit
Route ID	Street Name	Read Method	Trouble Code	Read Code 2	Low Limit
Read Date/Time	Note From Reader	Exception	Module # Meter #	Read Code 3	Present Read
0001008 1	Boyd	H - High	gab		0
0	16044 Lomand Cir	D - Interrogated			118052
03/30/16 15:55:36		L - Leak	83271016		121754
0001046 1	Martinez	H - High	gab		0
0	16073 Hi Land Cir	D - Interrogated			301274
03/30/16 15:55:32		L - Leak	83271078		307258
0001049 1	Robillard	H - High	gab		0
0	9580 E 160th Ave	D - Interrogated			281193
03/30/16 15:54:53		L - Leak	83271107		290302
0001052 1	Blanchard	H - High	gab		0
0	9889 E 159th Pl	D - Interrogated			180172
03/30/16 15:58:46		L - Leak	83270938		182063
0001058 1	Roos	H - High	gab		0
0	15940 Elmira St	D - Interrogated			436594
03/30/16 15:58:51		L - Leak	83271102		443558
0001084 1	Straface	H - High	gab		0
0	9984 E 158th Ave	D - Interrogated			1460746
03/30/16 15:42:32		L - Leak	83271009		1482455
0001098 1	Glynn	H - High	gab		0
0	9841 E 157th Ave	D - Interrogated			611642
03/30/16 15:37:37		L - Leak	83271035		617026
0001202 1	Master Meter	H - High	gab		0
0	Master Meter	D - Interrogated			1343000
03/30/16 15:56:26		L - Leak	82894197		1374000
0001203 1	WWTP	H - High	gab		0
0	WWTP	D - Interrogated			162183500
03/30/16 15:37:07		L - Leak	85733930		173776600

Total Number of Accounts: 9