

**ORC Water Professionals  
 Operations Report  
 January 2018  
 Prepared by:  
 Ashley Straub - Operator**

**Hi-Land Acres Water and Sanitation District**

**North Well**

- North well is fully operational.
- I contacted Julie with DPC to pick up the unused chlorine cannisters. Once the current cannisters are empty in a few weeks we will convert to the liquid sodium hypochlorite system.

**South Well**

- South well is having issues with a phase reversal, the motor will not turn on to fill the tank because of this. An electrician has been contacted to address the issue. Until it is fixed this side will remain off.

**WTP & Distribution System**

- The meter readings were sent to AMCOBI on 2-6-2018.
- Leak Listing:

<b>0001002 1</b>	<b>Bradley</b>	<b>H - High</b>	<b>AMS</b>
<b>0 0</b>	<b>16033 Hi Land Cir</b>	<b>D - Interrogated</b>	
<b>476749 02/01/18 10:25:47</b>		<b>L - Leak</b>	<b>83270752</b>
<b>486492</b>	.....	.....	.....
<b>0001004 1</b>	<b>Dill</b>	<b>H - High</b>	<b>AMS</b>
<b>0 0</b>	<b>16053 Hi Land Cir</b>	<b>D - Interrogated</b>	
<b>511554 02/01/18 10:26:05</b>		<b>U - No Usage</b>	<b>83270856</b>
<b>511554</b>	.....	.....	.....
<b>0001026 1</b>	<b>Malarkey</b>	<b>H - High</b>	<b>AMS</b>
<b>0 0</b>	<b>16134 Lomand Cir</b>	<b>d - Manual</b>	
<b>479200 02/01/18 10:28:29</b>			<b>83271794</b>
<b>486330</b>	.....	.....	.....
<b>0001043 1</b>	<b>Kiyota</b>	<b>H - High</b>	<b>AMS</b>
<b>0 0</b>	<b>16103 Hi Land Cir</b>	<b>D - Interrogated</b>	
<b>586233 02/01/18 10:26:37</b>		<b>L - Leak</b>	<b>83270947</b>
<b>606765</b>	.....	.....	.....
<b>0001049 1</b>	<b>Robillard</b>	<b>H - High</b>	<b>AMS</b>
<b>0 0</b>	<b>9580 E 160th Ave</b>	<b>D - Interrogated</b>	
<b>609063 02/01/18 10:30:53</b>		<b>L - Leak</b>	<b>83271107</b>
<b>629350</b>	.....	.....	.....

**WWTP**

- Lagoon 1 is nearly empty. A larger pump was required to get the remainder out.