

**ORC Water Professionals  
 Operations Report  
 March 2018  
 Prepared by:  
 Ashley Straub - Operator**

**Hi-Land Acres Water and Sanitation District**

**North Well**

- North well is fully operational.

**South Well**

- South well is fully operational.
- The testable RPZ for the waste water line was removed and the water line was disconnected.

**WTP & Distribution System**

- The sanitary survey with the state was conducted today (4/5/2018). Things went smoothly, for the most part. She had issues with the chlorine gas. Which isn't a major deal because we will be switching to liquid sodium hypochlorite. Her marking it as significant deficiencies should help us wiggle through the states approval plan a lot quicker. We will need Xuehuas help with the design to then get approved by the state.
- The meter readings were sent to AMCOBI on 4-2-2018.
- Leak Listing:

0001026 1	Malarkey	H - High	AMS
0 0	16134 Lomand Cir	d - Manual	
486330	04/02/18 13:24:27		83271794
496110	.....	.....	.....
0001043 1	Kiyota	H - High	AMS
0 0	16103 Hi Land Cir	D - Interrogated	
606765	04/02/18 13:22:43	L - Leak	83270947
629237	.....	.....	.....
0001049 1	Robillard	H - High	AMS
0 0	9580 E 160th Ave	D - Interrogated	
629350	04/02/18 13:22:43	L - Leak	83271107
647427	.....	.....	.....
0001058 1	Roos	H - High	AMS
0 0	15940 Elmira St	D - Interrogated	
622337	04/02/18 13:27:26	L - Leak	83271102
635520	.....	.....	.....
0001059 1	Addy	H - High	AMS
0 0	9988 E 159th Pl	D - Interrogated	
349191	04/02/18 13:27:35	L - Leak	83271834
354442	.....	.....	.....
0001064 1	Yamamoto	H - High	AMS
0 0	10039 E 159th Pl	D - Interrogated	
188861	04/02/18 13:27:18	L - Leak	83271644
194103	.....	.....	.....
0001094 1	Mohar	H - High	AMS
0 0	10043 E 157th Pl	D - Interrogated	

688709 04/02/18 13:37:16

L - Leak

83271280

704735 .....