

Hi-Land Acres Water and Sanitation District

North Well

- North well is fully operational.
- Approximately 50 lbs of gaseous chlorine is left. An order for everything has been put into DEWCO and I will get a notification when everything has been shipped in. We're waiting on design approval.

South Well

- South well is fully operational.
- Approximately 20 lbs of gaseous chlorine is left.

Distribution System

- Hydrant flushing is going to be conducted over the next few months as the weather will be nice. I will find a sign to put at the entrance so residents won't be alarmed.

Leak Listing:

• Reid	H - High	ams		0 0
16043 Hi Land Cir	D - Interrogated			679062
05/02/18 11:13:25		L - Leak	83271588	
690747				
• Malarkey	H - High	ams		0 0
16134 Lomand Cir	d - Manual			490430
05/02/18 11:16:21			83271794	
500000				
• Kiyota	H - High	ams		0 0
16103 Hi Land Cir	D - Interrogated			617677
05/02/18 11:14:13		L - Leak	83270947	
641784				
• Robillard	H - High	ams		0 0
9580 E 160th Ave	D - Interrogated			637857
05/02/18 11:18:49		L - Leak	83271107	
657932				
• Mohar	H - High	ams		0 0
10043 E 157th Pl	D - Interrogated			695492
05/02/18 11:24:20		L - Leak	83271280	
715949				
• Fortin	H - High	ams		0 0
9880 E 157th Ave	D - Interrogated			486289
05/02/18 11:24:10		L - Leak	83271594	
505108				