

**ORC Water Professionals
Operations Report
January 2015**

**Prepared by: Ernest Espinosa and Gabrielle Begeman, Facilities
Operators**

Hi-Land Acres Water and Sanitation District

North Well

The following events occurred at the North well over the course of the previous month.

- Has been running exceptionally well.
- 1 Chlorine gas cylinder has been ordered for system treatment

WTP & Distribution System

- The meter readings were sent to AMCOBI on 02/28/15.

South Well

- Insurance Roofers Inc., C&H Group Inc., has submitted the contract for approval from the board on 1/12/2015.
- 4 Chlorine gas cylinders have been ordered system treatment

WWTP

- The chlorine regulator faulted and the situation was corrected.
- The WWTP pump in detention pond failed and was pulled and fixed 2/15.

Collection System

- Review of system report finding
- Guildner has bid for the 15 point repairs that we recommend performing.