

Hi-Land Acres Water and Sanitation District

North Well

- North well has been put online to keep the system satisfied while the south well is down.
- Samples have been collected to reinstate the permanent status of the North well. We are awaiting results and final approval.
- The booster pump controls should be upgraded to enable alternation, better cycling and to eliminate the outdated equipment unintended for operation for the booster pumps via a constant pressure system that was installed back in January. This has been discussed with both Boulder Water Well and Applied Ingenuity in an attempt to provide a recommendation on a path to move forward. We are still reviewing the options.

South Well

- The south tanks were taken offline and cleaned and inspected while the well pump was being replaced. Both inspection reports are attached. We have received 2 estimates for repair of the tanks as recommended at the inspection. The tanks remain offline until a decision is made.
- We are purging the well weekly to review the water quality.

Distribution System

- The new meter reading software and reading equipment is working to provide almost all reads. There are 3 meters that require a manual read.
- Five (5) new meters have been ordered that will be placed in the Beacon system and will be read cellularly. These meters will be installed asap on the homes where they are needed.